



L1 - POWER "ON" INDICATOR

NOTE:

(1). 24 VAC COMMON, "-" OUTPUTS AND RIGHT POLE OF INPUT TERMINALS ARE TIED ELECTRICALLY TOGETHER.

(2) FOR 5A CTs BURDEN = 0.75VA  
(other burden resistors for different CTs)

**WARNING:** ALWAYS USE CURRENT TRANSFORMERS OR CURRENT SENSORS AS SPECIFIED FOR THE BOARD.

NEVER FEED THE LINE CURRENT DIRECTLY THROUGH THE BOARD

<b>ELCOR Technologies Inc.</b>		
DRAWN: PCK	TITLE: ETA3.BRD - WIRING DIAGRAM	CODE:
CHECKED: CKK		
DATE: 99-08-16	FILE: ..\tscad_drawings\ETA3_BRD.T3G	SHEET: 1 OF 1